

*Petroleum and Gas (Production and Safety) Act 2004*



**Queensland  
Government**

Petroleum and Gas Inspectorate

123 567 890

Full name: Barney Rubble  
Address: 4 Watermain Ave. Hosc. Qld

Telephone: 01 1234 5678  
Email: brubble@bigpond.com

## Gas system details

Location:	Granny Flat located at rear of Property			
Device:	Continuous	Hot Water	System	
Device make:	Thermann20			
Device model:	20LP50-6			
Serial number:	2018-02-6000-3767			
Approval number:	GMK10409			
Gas device type:	<input checked="" type="checkbox"/> A / <input type="checkbox"/> B	<input type="checkbox"/> A / <input type="checkbox"/> B	<input type="checkbox"/> A / <input type="checkbox"/> B	<input type="checkbox"/> A / <input type="checkbox"/> B
Gas capacity:	158 MJ/hr	MJ/hr	MJ/hr	MJ/hr
Operating pressure:	2.76 kPa	kPa	kPa	kPa
Fuel gas:	<input type="checkbox"/> Natural gas <input checked="" type="checkbox"/> LPG <input type="checkbox"/> Biogas <input type="checkbox"/> Syngas <input type="checkbox"/> Other:			
Fuel gas supplier:	<input type="checkbox"/> Self-supply <input checked="" type="checkbox"/> Supplier:			
Supply type:	<input checked="" type="checkbox"/> Exchange <input type="checkbox"/> In-situ fill <input type="checkbox"/> Network <input type="checkbox"/> Other:			
Supply pressure:	3 kPa (supply) / kPa (second stage regulator if a two-stage system)			

Date identified: 01-01-2019

Reason for safety concern:

☒ The gas system does not or may not comply with all relevant safety requirements.

☐ An imminent risk of material harm to persons or property is likely if action is not taken to avoid, eliminate or minimise the risk.

Description of safety concern (include a diagram if appropriate):

[illegible]

☒ I have a safety concern in relation to the gas system as detailed above and I have informed the owner, operator or proposed operator of the gas system.

☐ I have taken measures to avoid, eliminate or minimise the risk and I have reported the risk to the operator of the distribution system or LPG delivery network and the Petroleum and Gas Inspectorate.

GWL / GWA #:	A1234
Full name:	Gary Gasfitter
Signature:	
Date:	01-04-2010

Telephone: 01 5678 1234  
Email: gary.gasfitter@big.com

Please note that nothing in this document shall be regarded as in any way relieving you from compliance with the *Petroleum and Gas (Production and Safety) Act 2004*.

# Gas System Defect Notice information

Safety in the petroleum and fuel gas industry in Queensland is regulated under the *Petroleum and Gas (Production and Safety) Act 2004* (the Act) and the Petroleum and Gas (Safety) Regulation 2018 (the Regulation).

## Gas work

Gas work is the work of installing, removing, altering, repairing, servicing, testing or certifying the gas system of a gas device. Gas work must comply with the Act including all relevant safety requirements prescribed in the Regulation (such as mandatory and preferred standards).

A person must not carry out (or direct another person to carry out) gas work unless the person holds a gas work licence or authorisation that allows the person to carry out the work.

The holder of a gas work licence or authorisation is authorised under the Act to carry out gas work to the gas system of a gas device as stated, and subject to any limits and/or conditions imposed, in the decision and information notice relating to their gas work licence or authorisation.

## Safety obligations

A gas work licence or authorisation holder has a safety concern relating to a gas system if they know or suspect, or ought reasonably to know or suspect that:

- the gas system does not or may not comply with all relevant safety requirements; or
- an imminent risk of material harm to persons or property is likely if action is not taken to avoid, eliminate or minimise the risk.

## Action required

If a gas work licence or authorisation holder installs all or part of, or carries out gas work relating to, a gas system and has a safety concern relating to a gas system they must give the owner, operator or proposed operator notice of the noncompliance or risk (the safety concern) in the approved form (a Defect Notice).

If a gas work licence or authorisation holder believes there is an imminent risk of material harm to persons or property they must also:

- take appropriate measures to avoid, eliminate or minimise the risk
- immediately telephone the operator of the distribution system or fuel gas network and the Petroleum and Gas Inspectorate to report the risk and measures taken.

The Petroleum and Gas Inspectorate does not require a gas work licence or authorisation holder to give a Defect Notice if action is taken to immediately remedy the safety concern.

For more information, visit [www.business.qld.gov.au](http://www.business.qld.gov.au)

Please note that nothing in this document shall be regarded as in any way relieving you from compliance with the *Petroleum and Gas (Production and Safety) Act 2004*.