



Gas System Compliance Certificate

GSCC-620733

08 Mar 2022 12:17:43 PM (AEDT)

Owner, operator or proposed operator

Name: *Jonny Smithe*

Address: *12 First Avenue, Maroochydore, QLD, 4558, AU*

Phone: *0711119999* Email: *JS@gasowner.com*

Work completed

Installed all of a gas system

Gas system location

Commercial kitchen

Gas supply details

Network operator: *Other Free Gas 2U* Gas type: *LPG*

Supply: *Cylinder* Operating pressure (KPa): *70KPa*

Compliance plate: *Gas compliance plate attached and/or amended to identify details of gas work.*

Gas device details

Device 1

Device type: *A* Make: *Crispy Cookers Australia* Model: *Crispy Chip Fryer Delux* Serial number: *CCFD 112233*

Approval number: *GDAА 0101*

Commissioned: *Yes. This appliance has been commissioned and is now safe to be used.*

Instructions provided: *Yes. Gas appliance/device manufacturers installation, maintenance and operating instructions should be retained by the owner for future reference.*

Device 2

Device type: *B* Make: *Crispy Cookers Australia* Model: *Crispy Pizza Oven* Serial number: *CPO 1122* Approval number: *GDAА 0202*

Commissioned: *No. Appliances must not be used until commissioned by an authorised person.*

Instructions provided: *Yes. Gas appliance/device manufacturers installation, maintenance and operating instructions should be retained by the owner for future reference.*

Additional details of gas work / general comments

Installed new consumer piping at high level from LP Gas cylinder location in carpark to outside kitchen area, install 2nd stage regulator (70KPa to 3KPa) terminate vent away from openings and ignition source. Extend pipe into kitchen provide 1/4 turn emergency valve next to doorway. Pipe work at low level to fryer and pizza oven. Gas appliance isolation valves and pipe bump stops fitted. Fryer connected by gas hose assembly installed to hang in 'U' clear of floor, chain fitted on dog clip. Pipework tested (gastight) and purged. Fryer commissioned and left working. Pizza Oven left disconnected a valve, GWA Type b fitter to connect and commission.

Compliance certification

- I certify that the gas system and any gas work, as detailed above, complies with all relevant safety requirements.
- I have advised the owner, operator, in relation to the safe operation of the gas system.
- I will retain a copy of the completed certificate for at least 3 years.

Signature:



08/03/2022

GWL/GWA: L29752 Name: [REDACTED] Phone: 0711118899 Email: BM@gasfita.com

Please note that nothing in this document shall be regarded as in any way relieving you from compliance with the *Petroleum and Gas (Production and Safety) Act 2004*.

Petroleum and Gas Inspectorate approved form PGPSA734(3)(a), E- Version 1. Sept 21

Important information for gas system owners and operators

This certificate is an important document and should be kept safe for future reference.

Gas system owners have obligations under Queensland legislation to ensure –

- Gas appliances are used in a safe manner – Act s734AA
- Ensure suitable qualified person carries out gas work – Safety Regulations 97
- Not use a gas system if the owner is advised by a qualified person or inspector that the gas system is unsafe
- Ensure any safety concern raised by a gas system user is addressed – Safety Regulation s98

Privacy statement

A copy of this certificate will be provided to Resources, Safety and Health Queensland. Your personal information will be stored and used in accordance with RSHQ's obligation under *Information Privacy Act 2009*. Your personal information will not otherwise be disclosed to any other parties unless authorised or required by law. For further privacy information go to: Privacy statement (<http://www.rshq.qld.gov.au/help/legal/privacy>)